



OFFICE OF THE CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, ROHTAK

E-mail:-chemist.rohtak@gmail.com



Test Report

To

S.V.M International School
V.P.O. Baland
Rohtak

Memo No.- 349 Dated- 16/04/2024

Subject:- Report of chemical analysis of RO water sample

Reference:- Memo no Nil dated-12.04.2024

Please find enclosed here with 1 No. analysis report of RO water sample received from you on dated 12.04.2024 for information and further necessary action.

DA/As above

(Ms. Deepika)

Authorized Signatory/Chemist
PHED Water Testing Laboratory, Rohtak

Test Report

Issue Date: 16.04.2024

Test Report No. : RTK/00395/4/2024
 Issued To : S.V.M International School, Vpo Baland Rohtak
 Customer Reference No. : Nil
 Sample Type : RO Water sample
 Sample Collected by : Party self
 Sample received on dated : 12.04.2024
 Sample Location : S.V.M International School, Vpo Baland Rohtak
 Sample Quantity : 1Ltr
 Date of Analysis started : 15.04.2024
 Dated of analysis completed : 15.04.2024

RESULTS

Sr No.	Parameter	Protocol Used	Results	IS:10500:2012 (Second Revision) RA-2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
8	Sulphate (as So4)	USEPA	22	200	400	Mg/L
9	Fluoride (as F)	USEPA	1.06	1.0	1.5	mg/L
10	Iron(as Fe)	USEPA	0.01	1.0	No relaxation	Mg/L
11	Nitrate (as NO3)	USEPA	0.6	45	45	mg/L

Opinion: The sample confirms to the requirement of acceptable limit of drinking water as per IS 10500:2012 for the above tested parameter.

Notes:

1. The results given above are related to the sample as received and tested in PHED Lab, Rohtak. Reliability of sample lies with the sender.
2. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
3. The test report can't be used for any publicity or any legal purpose.
4. The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Deepika

(Ms.Deepika)

Authorized Signatory/Chemist
 PHED Water Testing Laboratory, Rohtak

END OF TEST REPORT